

Emergency Action

“Emergency Action” shall mean (1) any ~~emergency action for locational or system-wide capacity shortages that either utilizes pre-emergency mandatory load management reductions or other emergency capacity, or initiates a more severe action including, but not limited to, a megawatt~~ shortage of the Primary Reserve requirement (as specified in the PJM Manuals) in a Reserve Zone or Sub-Zone, inclusive of any adjustments to such requirement to account for system conditions, as determined by the dispatch run from the security constrained economic dispatch and where there is also a Voltage Reduction Warning and reduction of critical plant load, ~~Voltage Reduction Action, Manual Load Dump Warning, Maximum Emergency Generation Action, or Manual Load Dump Action~~ the curtailment of non-essential **building** loads and voltage reduction that encompasses such Reserve Zone or Reserve Sub-zone or (2) anytime the Office of Interconnection identifies an emergency and issues a load shed directive, Manual Load Dump Action, Voltage Reduction Action, or deploy all resources action for an entire Reserve Zone or Reserve Sub-zone.