



Cold Weather Generation Resource Preparation Update

OC Meeting
1/6/2015



Cold Weather Generation Operational Exercise - Status to Date

- As of 1/2/2014 approximately 156 units with a total ICAP of 9350 MW performed the cold weather generation operational exercise:

| Week of: | Units Exercised | | Success Rate |
|---------------------|-----------------|--------------|--------------|
| | Units | MWs | |
| Dec 5th | 21 | 659 | 57% |
| Dec 8th | 48 | 2893 | 89% |
| Dec 15th | 50 | 2937 | 88% |
| Dec 22nd | 4 | 242 | 75% |
| Dec 29th | 33 | 2618 | 70% |
| Jan 5th (projected) | 18 | 980 | |
| Total | 174 | 10329 | |

- Scheduling of units continuing into first week of January due to many cancellations in December related to weather

- By unit count, 91% indicated that they completed their own checklist or the checklist in Manual M14D
- By total ICAP, 98% indicated that they completed their own checklist or the checklist in Manual M14D
- For CT / Diesel / Steam / Combined Cycle units:
 - By unit count, 98% indicated that they completed their own checklist or the checklist in Manual M14D
 - By total ICAP, 99% indicated that they completed their own checklist or the checklist in Manual M14D

- Questions?
- Contact
 - coldweathergenprep@pjm.com
 - David Schweizer, 610-666-4503, david.schweizer@pjm.com
 - Ray Lee, 610-666-4608, ray.lee@pjm.com