



# Guideline: Generation Owner Periodic Tasks and Data Submittals

PJM Generation Department

October 2021

For Public Use

This page is intentionally left blank.

## Contents

Introduction.....	1
Required Tasks.....	1
<i>Summer/Winter Net Capability Verification</i> .....	1
<i>Black Start Testing</i> .....	2
<i>Voltage Schedule Review</i> .....	3
<i>eDART Reactive Capability Review</i> .....	3
<i>Cold Weather Checklist Data Request</i> .....	4
<i>Seasonal Fuel and Emissions Data Request</i> .....	4
<i>Periodic Data Requests</i> .....	5
<i>eDART GO Contact Data Request</i> .....	5
<i>NERC MOD-026/027 Data Submittals</i> .....	6
<i>Gen Model (MOD-032 for Generator Owners)</i> .....	7
<i>Resource Tracker Verification</i> .....	7
<i>Reactive Capability Testing</i> .....	8
<i>Capacity Modification Transaction</i> .....	9
<i>Restoration Drills</i> .....	9
<i>Variable Operating and Maintenance Cost (VOM) Review</i> .....	10
<i>Fuel Cost Policy Review</i> .....	10
<i>Emissions Data Submittal</i> .....	11
<i>Black Start Cost Submittal</i> .....	11
Optional Tasks.....	12
<i>Annual Grid Security Drill/GridEx</i> .....	12
<i>Regulation Testing</i> .....	12
<i>RTO Wide and Incremental Black Start RFPs</i> .....	13
<i>Unit-Specific Parameter Adjustment</i> .....	13
<i>Real-Time Values</i> .....	14
Attachment A .....	15

# Introduction

In order to assist PJM Generation Owners (GOs) with managing the various tasks, testing and data submittals required by PJM under the PJM Governing Agreements and Manuals, PJM has created this guideline. This guideline is not an all-inclusive list of items required of GOs by PJM’s Manuals and Governing Documents. It also does not address other external third party, regulatory or legal compliance requirements including but not limited to NERC Reliability Standards applicable to NERC-registered entities and FERC’s regulations. The liability of PJM, its Board, officers, employees and agents is governed by the applicable provisions of the PJM Tariff and Operating Agreement.

This document is broken into two sections: Required Tasks and Optional Tasks.

## Required Tasks

### Summer/Winter Net Capability Verification

#### Description

- Capability Verification testing is required of all generators that participate in the PJM Reliability Pricing Model (RPM) Capacity Markets or have a commitment in those markets.
- Summer Net Capability must meet or exceed the rated Installed Capacity (ICAP) and the claimed ICAP in PJM eGADS; Winter Net Capability must meet or exceed the rated ICAP and the claimed ICAP in PJM eGADS.

<b>Responsible PJM Department(s)</b> Resource Adequacy Planning	<b>Driver-/Requirement</b> <ul style="list-style-type: none"> <li>• PJM Manual 21, Rules and Procedures for Determination of Generating Capability</li> </ul>	
<b>Email Distribution List</b> <a href="mailto:gadssupport@pjm.com">gadssupport@pjm.com</a>	<ul style="list-style-type: none"> <li>• PJM Manual 18, PJM Capacity Market</li> </ul>	
<b>Periodicity:</b> Semiannual*	<b>Start Date:</b> June 1   Dec. 1	<b>End Date:</b> Aug. 31   Feb. 28–29
<b>System Used To Collect Data</b> <a href="#">eGADS</a>	<b>Required or Optional?</b> Required	

\* Winter verification tests can be summer tests corrected to winter conditions. Hydro units test only in the summer; no winter verification test is required for hydro units.

## Black Start Testing

### Description

Black Start units test their ability to start without outside power and remain in a stable operating state while running at minimum generation levels. Tests are conducted at plant by GO and sent to PJM for review, pass/fail determination, and record keeping.

### Driver/Requirement

#### Black Start Units Compensated by PJM

- OATT Schedule 6A, Section 12: To verify that they can be started and operated without being connected to the Transmission System, Black Start Units designated as critical shall be tested annually in accordance with the PJM manuals. The Black Start Unit owner shall determine the time of the annual test.
- OATT Schedule 6A, Section 14: To receive Black Start Service revenues, a Black Start Unit must have a successful annual test on record with the Transmission Provider within the preceding 13 months.
- PJM Manual 12, Section 4.6.14: To collect monthly Black Start revenues, a unit must have a successful Black Start test on record with PJM within the last 13 months. Once a generator is qualified, they have until the end of the 13th month following the last successful Black Start test date to submit documentation of the next successful annual test to PJM.
- If a unit fails a Black Start test, the unit is given a 10-day grace period within which it may retest without financial penalty if within the 13-month testing period.
- If the unit does not successfully pass a Black Start test within the 10-day grace period immediately following notification to PJM of a failed test, monthly Black Start revenues will be forfeited from the time of the first day of the month in which the unsuccessful test occurred until the first day of the first month after the unit successfully passes a Black Start test.

#### Black Start Units Not Compensated by PJM

- NERC Standard EOP-005, System Restoration from Blackstart Resources, R7: Each Transmission Operator shall have Blackstart Resource testing requirements to verify that each Blackstart Resource is capable of meeting the requirements of its restoration plan. These Blackstart Resource testing requirements shall include:
  - R7.1: The frequency of testing such that each Blackstart Resource is tested at least once every three calendar years.
  - R7.2: A list of required tests including:
    - R7.2.1: The ability to start the unit when isolated with no support from the BES or when designed to remain energized without connection to the remainder of the System
    - R7.2.2: The ability to energize a bus. If it is not possible to energize a bus during the test, the testing entity must affirm that the unit has the capability to energize a bus such as verifying that the breaker close coil relay can be energized with the voltage and frequency monitor controls disconnected from the synchronizing circuits.

### Responsible PJM Department(s)

Performance Compliance

### Email Distribution List

[Blackstart@pjm.com](mailto:Blackstart@pjm.com)

### Periodicity

- *Testing periodicity of Critical Black Start Units: 1–3 months*
- *Review, pass/fail determination and record keeping: monthly*

**Start Date:** Varies depending on in-service date

**End Date:** Varies depending on in-service date

### System Used To Collect Data

[eDART](#) | Microsoft Excel | Microsoft Access

### Required or Optional?

*Critical Black Start Units: Required*

*Noncritical Black Start Units: Optional*

## Voltage Schedule Review

### Description

Annual review of PJM maintained voltage schedules assigned by the TO, acknowledged by the GO and approved by PJM. The annual review consists of two parts:

- TOs review and update voltage schedules.
- GOs review and acknowledge voltage schedules.

<b>Responsible PJM Department(s)</b> Generation	<b>Driver/Requirement</b> <ul style="list-style-type: none"> <li>• NERC Standard VAR-001, Voltage and Reactive Control</li> <li>• PJM Manual 3, Transmission Operations, Section 3.11</li> </ul>
<b>Email Distribution List</b> <a href="mailto:voltageschedules@pjm.com">voltageschedules@pjm.com</a>	
<b>Periodicity</b> Annual; Requires one month each to complete review by TO and GO	
<b>Start Date:</b> April 1	<b>End Date:</b> May 31
<b>System Used To Collect Data:</b> <a href="#">eDART</a>	<b>Required or Optional?</b> Required

## eDART Reactive Capability Review

### Description

To ensure accuracy of generator reactive capabilities that may result from planned unit modifications, a critical input to PJM and TO security analysis packages, PJM requires that each GO review and confirm their unit reactive capability data via eDART on a biannual basis. PJM and the TOs should then verify accuracy of unit reactive capabilities modeled in their respective EMS systems.

<b>Responsible PJM Department(s)</b> Generation	<b>Driver/Requirement</b> PJM Manual 14-D, Generator Operational Requirements, Section 7.3.4, Generating Unit Reactive Capability Reporting
<b>Email Distribution List</b> <a href="mailto:GenOutageSupport@pjm.com">GenOutageSupport@pjm.com</a>	
<b>Periodicity</b> Semiannual: <i>Generation Owners: April &amp; October   Transmission Owners: May &amp; November</i>	
<b>Start Date:</b> <ul style="list-style-type: none"> <li>• April 1 &amp; May 1</li> <li>• Oct. 1 &amp; Nov. 1</li> </ul>	<b>End Date:</b> <ul style="list-style-type: none"> <li>• April 30 &amp; May 31</li> <li>• Oct. 31 &amp; Nov. 30</li> </ul>
<b>System Used To Collect Data:</b> <a href="#">eDART</a>	<b>Required or Optional?</b> Required

## Cold Weather Checklist Data Request

### Description

PJM expects all generation resources to use a cold weather preparation checklist prior to the National Oceanic and Atmospheric Administration (NOAA) first frost date to prepare for cold weather operations to promote reliability.

To verify and document the practice, generation resources are required to complete the Cold Weather Checklist Data Request issued by PJM.

<b>Responsible PJM Department(s)</b> Generation	<b>Driver/Requirement</b>	
	<ul style="list-style-type: none"> <li>PJM Manual 14-D, Generator Operational Requirements, Section 7.5.2 Generation Resource Cold Weather Checklist</li> <li>NERC Reliability Guideline: Generating Unit Winter Weather Readiness – Current Industry Practices</li> </ul>	
<b>Email Distribution List</b> <a href="mailto:edartgosurvey@pjm.com">edartgosurvey@pjm.com</a>		
<b>Periodicity:</b> Annual	<b>Start Date:</b> Nov. 1	<b>End Date:</b> Dec. 15
<b>System Used To Collect Data</b> <a href="#">eDART</a>	<b>Required or Optional?</b> Required	

## Seasonal Fuel and Emissions Data Request

### Description

The Seasonal Fuel and Emissions Data Request requires all generation resources to report fuel and emissions data so that in severe situations PJM has the situational awareness to make decisions to promote the reliable operation of the electric grid.

PJM needs data concerning unit fuel reserves and emissions limitations for it to reliably operate the PJM Balancing Authority and its associated markets. This is especially true during periods of severe weather and/or times when there are external fuel constraints.

<b>Responsible PJM Department(s)</b> Generation	<b>Email Distribution List</b> <a href="mailto:edartgosurvey@pjm.com">edartgosurvey@pjm.com</a>	
<b>Driver-/Requirement</b>		
<ul style="list-style-type: none"> <li>PJM Manual 14-D, Generator Operational Requirements, Section 7.3.5 Fuel and Emissions Reporting</li> <li>PJM Operating Agreement Sections 11.3 Member Responsibilities, 11.3.1 General, and Definition of Emergency, “Emergency’ shall mean: ... (ii) a fuel shortage requiring departure from normal operating procedures in order to minimize the use of such scarce fuel”</li> <li>NERC Reliability Standard, EOP-11, Emergency Operations</li> </ul>		
<b>Periodicity:</b> Annual	<b>Start Date:</b> Approx. Oct. 1	<b>End Date:</b> Approx. Nov. 15
<b>System Used To Collect Data</b> <a href="#">eDART</a>	<b>Required or Optional?</b> Required	



## Periodic Data Requests

### Description

Depending on the severity of the weather forecasts, projected fuel availability, responses to the Seasonal Fuel and Emission Data Request, or other reasons, PJM may request on a periodic basis updated responses to the Seasonal Fuel and Emission Data Request questions for a subset of units. This information is intended to assist in the Operations Planning process.

**Responsible PJM Department(s)**  
Generation

**Email Distribution List**  
[edartgosurvey@pjm.com](mailto:edartgosurvey@pjm.com)

### Driver/Requirement

- PJM Manual 14-D, Generator Operational Requirements, Section 7.3.5 Fuel and Emissions Reporting;
- PJM Operating Agreement Sections 11.3 Member Responsibilities, 11.3.1 General, and definition of Emergency, “Emergency’ shall mean: ... (ii) a fuel shortage requiring departure from normal operating procedures in order to minimize the use of such scarce fuel”
- NERC Reliability Standard, EOP-11, Emergency Operations

**Periodicity:** As required

**Start Date:** As required

**End Date:** As required

**System Used To Collect Data:** [eDART](#)

**Required or Optional?** Required

## eDART GO Contact Data Request

### Description

“As soon as practicable, but no later than 3 business days following a generation transfer or a new generation resource being placed in commercial operation, the ‘eDART Contact’ responsible for tickets and data submittals in eDART must complete the eDART Contact Data Request – all fields are required. The Data Request is accessed by selecting the ‘Gen. Tickets’ menu item and the selecting GO Contact Data Request from the GO Data Request menu.

Name, Title, Role and Company of the primary and secondary individuals responsible for handling eDART functions. Email, Desk and Mobil Phone Numbers of the primary individual responsible for handling eDART functions. Name, phone number and Email of the primary individual or group that should be contacted for any operational issues and/or questions. This MUST be a group that can respond 24 hours a day, 7 days a week, 365 days a year. Name, phone number and Email of the secondary individual or group that should be contacted for any operational issues and/or questions. This MUST be a group that can respond 24 hours a day, 7 days a week, 365 days a year. Email Address of the group that should be contacted for any Voltage Schedule issues and/or questions.”

**Responsible PJM Department(s)**  

- Generation
- Member Relations

**Email Distribution List**  
[edartgosurvey@pjm.com](mailto:edartgosurvey@pjm.com)

**Driver/Requirement**  
PJM Manual M-14D, Generator Operational Requirements, Section 5.7.2.10

**Periodicity** Addition of information within three days of new unit addition or transfer.

**Start Date:** Varies

**End Date:** Varies

**System Used To Collect Data:** [eDART](#)

**Required or Optional?** Required



## NERC MOD-026/027 Data Submittals

### Description

In order to verify that the dynamic model and the model parameters used in dynamic simulations that assess Bulk Electric System (BES) reliability accurately represent generator unit real power response to system frequency variations, GOs submit a report providing model parameters and plots proving the simulated response matches a recorded response. PJM determines if the provided models are “usable” or “not usable” by verifying they can initialize and pass several simulation tests designed to ensure they will function in the interconnection-wide models, in addition to comparing PJM simulations to reported simulation results.

Once an updated dynamic model is found useable, it is included in all future planning dynamics case builds and is passed to Operations to update the real-time Transient Stability Analysis Tool (TSAT).

<p><b>Responsible PJM Department(s)</b> System Planning Modeling and Support</p> <p><b>Email Distribution List</b> <a href="mailto:NERC.Transmission.Planner@pjm.com">NERC.Transmission.Planner@pjm.com</a></p>	<p><b>Driver/Requirement</b></p> <ul style="list-style-type: none"> <li>• <i>NERC Standard MOD-026</i> – Verification of Models and Data for Generator Excitation Control System or Plant Volt/Var Control Functions</li> <li>• <i>NERC Standard MOD-027-1</i> – Verification of Models and Data for Turbine/Governor and Load Control or Active Power/Frequency Control Functions</li> </ul>
<p><b>Periodicity</b></p>	<ul style="list-style-type: none"> <li>• Within 365 days of going in-service or making an equipment change</li> <li>• Subsequent verification on or before the 10-year anniversary of the last transmittal</li> </ul>
<p><b>Start Date:</b> Varies</p>	<p><b>End Date:</b> Varies</p>
<p><b>System Used To Collect Data</b> <a href="#">PJM Planning Community</a></p>	<p><b>Required or Optional?</b></p> <ul style="list-style-type: none"> <li>• <i>Required</i> for applicable generators (Individual generating unit greater than 100 MVA (gross nameplate rating) or individual generating plant consisting of multiple generating units that are directly connected at a common BES bus with total generation greater than 100 MVA (gross aggregate nameplate rating)).</li> <li>• <i>Optional</i> for generators not meeting the applicability criteria in the standard.</li> </ul>

## Gen Model (MOD-032 for Generator Owners)

### Description

**What is the data?** Generator data needed for load flow, short circuit, and dynamics modeling. Complete set of data requirements available on PJM Planning Center website.

**Why is it needed?** To verify and update planning models.

**How is it used?** On an ad-hoc basis (working toward adding more regularity and structure to this), Gen Model data is compared with existing modeling data, and if discrepancies are identified, they are confirmed with the GOs (or GO corrects invalid data) prior to implementing to update the model(s).

---

<b>Responsible PJM Department(s)</b> System Planning Modeling and Support	<b>Driver/Requirement</b> <ul style="list-style-type: none"> <li>• NERC Standard MOD-032 – Data for Power System Modeling and Analysis</li> <li>• PJM requirements:                         <ul style="list-style-type: none"> <li>- <a href="https://pjm.com/planning/services-requests/planning-modeling-submission-mod-032.aspx">https://pjm.com/planning/services-requests/planning-modeling-submission-mod-032.aspx</a></li> <li>- <a href="#">MOD-032 Steady State, Dynamics and Short Circuit Modeling Data Requirements and Procedures</a></li> <li>- <a href="#">PJM Planning Center: Gen Model User Guide</a></li> </ul> </li> </ul>
<b>Email Distribution List</b> <a href="mailto:MOD-032@pjm.com">MOD-032@pjm.com</a>	

### Additional Guidance

[PJM Compliance Bulletin CB022 – MOD-032-1 Data for Power Systems Modeling & Analysis](#)

---

<b>Periodicity:</b> Annual	<b>Start Date:</b> May 1	<b>End Date:</b> June 15
----------------------------	--------------------------	--------------------------

---

<b>System Used To Collect Data</b> PJM Gen Model Portal	<b>Required or Optional?</b> <ul style="list-style-type: none"> <li>• Required by NERC Standard for all NERC-registered generators-</li> <li>• Required by PJM for non-NERC generators that participate in the capacity market or non-capacity generators with nameplate rating &gt;=20MW</li> </ul>
--	--

---

## Resource Tracker Verification

### Description

PJM requires a GO to have a single point of contact for real-time and near real-time operations. That single point of contact has to communicate and coordinate with the appropriate PJM member corporate entity to fulfill the assigned responsibilities.

---

<b>Responsible PJM Department(s)</b> Member Relations	<b>Driver-/Requirement</b> PJM Manual 14-D, Generator Operational Requirements, Section 5.3.7 Resource Tracker supports the maintenance of ownership information and provides the user the ability to review all sources of ownership information. GO, or designated agent, is required to confirm the resource ownership information.
<b>Email Distribution List</b> <a href="mailto:ResourceTrackerSupport@pjm.com">ResourceTrackerSupport@pjm.com</a>	
<hr/> <b>Periodicity</b> Annual, and if a generator is transferred to another entity (two business days after transfer)	
<hr/> <b>Start Date:</b> Oct 1 or upon generation transfer <b>End Date:</b> Nov. 1 or upon generation transfer	
<hr/> <b>System Used To Collect Data:</b> <a href="#">Resource Tracker</a> <b>Required or Optional?</b> Required	

---

## Reactive Capability Testing

### Description

“PJM requires testing to be coordinated between PJM, the testing facility and the local Transmission Owner’s (TO) to ensure that the impact on system operations is minimized. Testing is intended to demonstrate reactive capability for those conditions where reactive reserves or voltage control would be required.

The testing covered in Attachment E is designed to demonstrate useable reactive capability and, unlike real power (MW) capacity testing, not a maximum capability test. It is the intent of these procedures to align with NERC Reliability Standard MOD-025 so separate tests to meet the NERC requirements and the PJM requirements are not needed.

The following facilities are required to perform reactive capability testing:

- Individual generating units and inverter-based Energy Storage Resources with a gross nameplate rating greater than 20 MVA and directly connected to the Bulk Electric System.
- Generating plants/facilities with a gross aggregate nameplate rating greater than 75 MVA including inverter-based Energy Storage Resources, and variable resources such as wind, solar, run of river hydro, etc.
- Synchronous condensers with a gross nameplate rating greater than 20 MVA and directly connected to the Bulk Electric System
- All generating units providing PJM Black Start Service”

<b>Responsible PJM Department(s)</b> Performance Compliance	<b>Driver/Requirement</b> <ul style="list-style-type: none"> <li>• NERC Standard MOD-025– Verification and Data Reporting of Generator Real and Reactive Power Capability and Synchronous Condenser Reactive Power Capability</li> <li>• PJM Manual 14-D Generator Operational Requirements, Attachment ‘E’</li> </ul>
<b>Email Distribution List</b> <a href="mailto:ReactiveTesting@pjm.com">ReactiveTesting@pjm.com</a>	
<b>Periodicity</b> Minimum of five every years	
<b>Start Date:</b> Varies based on previous test date	<b>End Date:</b> Varies based on previous test date
<b>System Used To Collect Data</b> <a href="#">eDART</a>	<b>Required or Optional?</b> Required for generators specified above

## Capacity Modification Transaction

### Description

CAPMODs are a type of Capacity Exchange transaction used by GOs to request the addition of a new unit or the removal of an existing unit from their resource portfolio in Capacity Exchange, or to request a MW increase or decrease in the summer or winter installed capacity rating of an existing unit.

<b>Responsible PJM Department(s)</b> Capacity Market Operations	<b>Driver/Requirement</b> <ul style="list-style-type: none"> <li>PJM Open Access Transmission Tariff (OATT), Attachment DD, Section 5.6.6</li> <li>PJM Manual 18, PJM Capacity Market, Section 4.2.6</li> </ul>
<b>Email Distribution List</b> <a href="mailto:RPM_Hotline@pjm.com">RPM_Hotline@pjm.com</a>	
<b>Periodicity</b>	When permanent changes to the installed capacity value of a generation unit are necessary
<b>Start Date:</b> N/A	<b>End Date:</b> N/A
<b>System Used To Collect Data</b> <a href="#">Capacity Exchange</a>	<b>Required or Optional?</b> Required

## Restoration Drills

### Description

All generation facilities identified in PJM TO Restoration Plans that are invited to participate in restoration drill are required to participate.

<b>Responsible PJM Department(s)</b> State and Member Training	<b>Driver-/Requirement</b> <ul style="list-style-type: none"> <li>NERC Standard EOP-005, System Restoration Plans</li> <li>NERC Standard EOP-006, System Restoration Coordination</li> <li>PJM Manual 36, System Restoration, Attachment 'D'</li> </ul>
<b>Email Distribution List</b> <a href="mailto:TrainingSupport@pjm.com">TrainingSupport@pjm.com</a>	
<b>Periodicity</b>	Varies, at least once annually
<b>Start Date:</b> Varies, subject to scheduling constraints; commonly during spring	<b>End Date:</b> Varies, similar to the start date
<b>System Used To Collect Data</b> <ul style="list-style-type: none"> <li><a href="#">Resource Tracker</a> used to track company contacts.</li> <li><a href="#">PJM Learning Management System (LMS)</a> is used to document drill participation.</li> </ul>	<b>Required or Optional?</b> Required (if invited to participate) – NERC Compliance

## Variable Operating and Maintenance Cost (VOM) Review

### Description

Maintenance expenses are associated with the repair or replacement of equipment due to wear and tear from electric production. Operating costs are expenses related to consumable materials used during unit operation. Maintenance expenses and operating costs are recoverable through the energy market. Only expenses/costs incurred as a result of electric production based on operating hours, starts, or a combination of operating hours and starts qualify for inclusion. Fixed costs cannot be included.

In order to utilize a VOM adder with a cost-based offer, the maintenance expenses and operating costs must be submitted to PJM and the Market Monitoring Unit (MMU) for review annually. Maintenance and operating cost adders must be approved before they can be included in the MarketSeller's cost-based offer. Approved VOM adders expire Dec. 31 of the year following acceptance.

Responsible PJM Department(s)	Email Distribution List	Driver/Requirement
Performance Compliance Department	<a href="mailto:FuelCostPolicyAnalysis@pjm.com">FuelCostPolicyAnalysis@pjm.com</a>	Operating Agreement Schedule 2 Section 4

**Periodicity** Annual

**Start Date:** June 15 (as early as Jan. 1), or as needed      **End Date:** Dec. 31

System Used To Collect Data	Required or Optional?
<a href="https://connect.pjm.com">connect.pjm.com</a> – SharePoint	Required for any unit submitting a VOM adder on their cost-based offer

## Fuel Cost Policy Review

### Description

Market Sellers that offer a generation resource, including external capacity and energy-only resources, and submit a non-zero cost-based offer (including negative offers) in the PJM Interchange Energy Market, must have a PJM-approved Fuel Cost Policy consistent with each fuel type on which the resource can operate. Regulation-only resources do not require a Fuel Cost Policy.

Prior to expiration of a Fuel Cost Policy, all MarketSellers will be required to either submit to PJM and the Market Monitoring Unit an updated Fuel Cost Policy that complies with this Operating Agreement, Schedule 2, and PJM Manual 15, or confirm that their expiring Fuel Cost Policy remains compliant.

Responsible PJM Department(s)	Email Distribution List	Driver/Requirement
Performance Compliance Department	<a href="mailto:FuelCostPolicyAnalysis@pjm.com">FuelCostPolicyAnalysis@pjm.com</a>	Operating Agreement Schedule 2, Section 2

**Periodicity** Periodic review currently occurs every three years

**Start Date:** Jan. 1 on year of expiration, or whenever new policy is submitted      **End Date:** Nov. 1 on year of expiration, or 30 business days after new policy is submitted

System Used To Collect Data	Required or Optional?
	Required for any unit submitting a non-zero cost-based offer

Monitoring Analytics' Member  
Information Reporting Application  
(MIRA) tool

### **Emissions Data Submittal**

#### **Description**

Market Sellers may elect, but are not required, to include emissions adders in their cost-based energy offer. Market Sellers must indicate, in their unit's Fuel Cost Policy, if they are including emissions adders in their cost offers. Emissions rates must be submitted to PJM, via COA, and be approved before they can be included in the Market Seller's cost-based offer.

<b>Responsible PJM Department(s)</b>	<b>Email Distribution List</b>	<b>Driver/Requirement</b>
Performance Compliance Department	<a href="mailto:FuelCostPolicyAnalysis@pjm.com">FuelCostPolicyAnalysis@pjm.com</a>	Operating Agreement Schedule 2, Section 3

**Periodicity** Annual

**Start Date:** June 15 (Data may be submitted as early as Jan. 1)      **End Date:** Dec. 31

<b>System Used To Collect Data</b>	<b>Required or Optional?</b>
<ul style="list-style-type: none"> <li>EPA</li> <li>Monitoring Analytics' MIRA tool</li> <li>Cost Offer Assumptions (COA) module</li> </ul>	Required for any unit that specifies in their Fuel Cost Policy that they use non-zero Emissions adders in their cost offers

### **Black Start Cost Submittal**

#### **Description**

On an annual basis, Black Start generators must submit data for their annual revenue calculation, which consists of fixed Black Start Service costs (capital), variable Black Start Service costs (VOM) and fuel storage costs related to providing Black Start Service.

<b>Responsible PJM Department(s)</b>	<b>Email Distribution List</b>	<b>Driver/Requirement</b>
Performance Compliance Department	<a href="mailto:blackstart@pjm.com">blackstart@pjm.com</a>	OATT Schedule 6A, Section 17 A

**Periodicity** Annual

**Start Date:** May 3      **End Date:** May 27

<b>System Used To Collect Data</b>	<b>Required or Optional?</b>
<ul style="list-style-type: none"> <li>Monitoring Analytics' MIRA tool</li> <li><a href="#">eDART</a></li> </ul>	Required for all Black Start Units

## Optional Tasks

### Annual Grid Security Drill/GridEx

#### Description

Grid security drills test the reliability and resilience of PJM and member company procedures, practices, technology and logistical support to events that affect the bulk electric system.

#### Responsible PJM Department(s)

- System Operator Training
- State and Member Training
- Business Continuity Planning

#### Driver/Requirement

- PJM Manual 40, Training and Certification Requirements, Section 3.2.2 Market Operation Center Generation Dispatchers Certification Requirements
- NERC Standard PER-005-2, Operations Personnel Training
- NERC Standard EOP-011-1, Emergency Operations

#### Email Distribution List

[bc\\_planning@pjm.com](mailto:bc_planning@pjm.com)

**Periodicity** Biannually

**Start Date:** During the month of November **End Date:** During the month of November

#### System Used To Collect Data

Participation forms

#### Required or Optional?

Optional

### Regulation Testing

#### Description

If units elect to participate in the regulation market, they will need to pass a series of tests in order to qualify. All testing requirements are identified in PJM Manual 12, Balancing Operations, Section 4.5, as well as links that need to be created in Manual 12, Section 4.4. Other reasons that units may need to test are identified in the manual as well. This includes change of ownership and change to signal paths.

#### Responsible PJM Department(s)

Performance Compliance

#### Driver/Requirement

Manual 12, Balancing Operations, Section 4.4, 4.5

#### Email Distribution List

[RegulationTesting@pjm.com](mailto:RegulationTesting@pjm.com)

**Periodicity** Upon request by Market Seller

**Start Date:** N/A **End Date:** N/A

#### System Used To Collect Data

- Email (test scheduling and follow-up)
- PI (for scoring test)

#### Required or Optional?

Optional



## RTO Wide and Incremental Black Start RFPs

### Description

PJM issues an RTO-Wide Black Start RFP every five years to identify new or replacement Black Start to enhance overall restoration reliability and efficiency. PJM may issue Incremental Black Start RFPs due to unit retirements, Black Start Service terminations or critical loads additions/removals. PJM's Black Start RFP process is used to meet minimum Black Start requirements defined in PJM Manual 36 System Restoration, Attachment A.

<b>Responsible PJM Department(s)</b> Generation	<b>Driver/Requirement</b>	
<b>Email Distribution List</b> <a href="mailto:blackstart@pjm.com">blackstart@pjm.com</a>	<ul style="list-style-type: none"> <li>PJM Manual 14D, Section 10 Black Start Generation Procurement</li> <li>PJM Manual 36, Attachment A, Minimum Critical Black Start Requirement</li> </ul>	
<b>Periodicity</b>	RTO Wide – Every five years, with awarded Black Start Resources entering service within 24 months of award; Incremental, as needed	
<b>Start Date:</b>	<ul style="list-style-type: none"> <li>Initiated RTO-Wide RFP 2018 to have new Black Start resources available in 2020</li> <li>Process repeats every five years</li> </ul>	<b>End Date:</b> Refer to PJM Manual 14-D, Generator Operational Requirements, Section 10 for Black Start procurement timelines-
<b>System Used to Collect Data</b> Email – Interested parties respond to RFP via email to <a href="mailto:blackstart@pjm.com">blackstart@pjm.com</a>	<b>Required or Optional?</b> Optional	

## Unit-Specific Parameter Adjustment

### Description

Market Sellers that do not believe their individual resources can meet the unit-specific parameter limits determined by PJM due to actual operating constraints, can request that PJM establish adjusted unit-specific parameter limits for those resources on their price-based Parameter Limited Schedule (PLS and cost-based schedules).

<b>Responsible PJM Department(s)</b> Generation & Day-Ahead Market Operations	<b>Driver/Requirement</b>	
<b>Email Distribution List</b> <a href="mailto:unitspecificpls@pjm.com">unitspecificpls@pjm.com</a>	<ul style="list-style-type: none"> <li>PJM Open Access Transmission Tariff (OATT), Attachment K, Section 6.6</li> <li>PJM Operating Agreement (OA) Schedule 1, Section 6.6</li> <li>PJM Manual 11, Energy &amp; Ancillary Services Market Operations, Section 2.3.4.2</li> </ul>	
<b>Periodicity</b>	Annual	
<b>Start Date:</b>	March 1	<b>End Date:</b> Feb. 28
<b>System Used To Collect Data</b> Email – Microsoft Excel spreadsheet sent to <a href="mailto:unitspecificpls@pjm.com">unitspecificpls@pjm.com</a>	<b>Required or Optional?</b> Optional	

## Real-Time Values

### Description

“Market Sellers can communicate the resource’s current operational capabilities to PJM before and after the Day-ahead Energy Market closes through the ‘Real Time Values’ function in Markets Gateway. Real Time Values should be utilized when a resource cannot operate according to the unit specific parameters or approved Parameter Limit Exceptions.”

---

### Responsible PJM Department(s)

- Generation Department
- Day-Ahead Market Operations Department

### Driver/Requirement

Manual 11, Energy & Ancillary Services Market Operations, Section 2.3.4.4

### Email Distribution List

[realtimevalues@pjm.com](mailto:realtimevalues@pjm.com)

---

**Periodicity** Up to 30 days when RTV is submitted

---

**Start Date:** As needed

**End Date:** As needed

---

**System Used To Collect Data**

Markets Gateway

**Required or Optional?**

Optional

---

# Attachment A

Color Key: ■ Required Tasks ■ Required for Specific Gens. ■ Required If Invited ■ Optional ● Start Date ● End Date

	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sept.	Oct.	Nov.	Dec.
<b>YEARLY TASKS</b>	<b>eDART Reactive Capability Review</b> Semiannual April 1–30 (GO) <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> May 1–31 (TO) <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span>											
	<b>Cold Weather Checklist Data Request</b> Nov. 1–Dec. 15 <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span>											
	<b>Resource Tracker Verification</b> *Within 3 days of ops. or transfer *Oct. 1–Nov. 1 <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span>											
	<b>Seasonal Fuel and Emissions Data Request</b> ~ Oct. 1–Nov. 15 <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span>											
	<b>Summer / Winter Net Capability Verification (Semiannual)</b> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> June 1–Aug. 31 <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> Dec. 1–Feb. 28/29 <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span>											
	<b>Voltage Schedule Review</b> April 1–May 31 <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span> <span style="color: #e91e63;">●</span>											
	<b>Black Start Cost Submittal</b> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> May 3–27											
	<b>Emissions Data Submittal</b> (Typically June 15) <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> Jan. 1 <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> June 15–Dec. 31											
	<b>Fuel Cost Policy Review</b> Expiration year/new policy submitted; **or 30 days after new policy <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> Jan. 1–**Nov. 1											
	<b>Gen Model (MOD-032 for Generator Owners)</b> May 1–June 15 <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span>											
	<b>VOM Review (Typically June 15 or as needed)</b> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> Jan. 1 <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> <span style="color: #004a7c;">●</span> June 15–Dec. 31											
	<b>Annual Grid Security Drill / GridEx</b> Biannual During the month of Nov. <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span>											
	<b>Restoration Drills (Typically spring)</b> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span> <span style="color: #ffc107;">●</span>											
	<b>RTO Wide Black Start RFPs (Every 5 years)</b> Every 5 years											
	<b>Unit Specific Parameter Adjustment</b> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> <span style="color: #42a5f5;">●</span> March 1–Feb 28											
<b>AS REQUIRED</b>	<b>Capacity Modification Transaction</b> When permanent changes to the installed capacity value of a gen. unit is necessary											
	<b>eDART GO Contact Data Request</b> Within 3 days of new unit addition or transfer											
	<b>Periodic Data Requests</b> Requested by PJM when needed											
	<b>Black Start Testing</b> Optional for Noncritical Black Start Units 1- to 13-month month test period and dependent on in-service date											
	<b>NERC MOD-026/027 Data Submittals</b> Optional for gens not meeting criteria Within year of going in-service/making equipment changes											
	<b>Reactive Capability Testing</b> (See document for details) Minimum of 5 every year											
	<b>Regulation Testing</b> Upon request by Market Seller											
	<b>Incremental Black Start RFPs</b> Black Start Service provided within 24 months of award											
<b>Real-Time Values (RTV)</b> Up to 30 days when RTV is submitted												

Updated Oct. 2021