



# Market Efficiency Proposal Window 2016-2017 Long Term Proposal Window 1A

- Addendum 2016-2017 Long Term Proposal Window 1A
  - Opened on September 14, 2017
  - Closed on September 28, 2017.
  - Solicited proposals to address the Tanners Creek - Dearborn 345 kV thermal constraint, which is a Reliability Pricing Model (RPM) constraint.
- Target facility Tanners Creek - Dearborn 345 kV is the next limiting element in the 2020/2021 RPM Base Residual Auction CETL study for the DEOK LDA\*
- Data posted on the PJM website:
  - <http://www.pjm.com/planning/rtep-development/expansion-plan-process/ferc-order-1000/rtep-proposal-windows/2016-2017-rtep-long-term-proposal-window.aspx>

\*After RTEP baseline upgrade b2831 (Upgrade the Tanner Creek - Miami Fort 345 kV circuit) is constructed

- 3 Market Efficiency Proposals
  - 1 Greenfield
    - \$12.7M
  - 2 Upgrades
    - \$0.6 - \$4.9M
- 2 proposing entities
  - LS Power
  - AEP

- **PJM Analysis Completed**
  - Determined CETL impact of proposed projects (see next slide)
  - Completed 2020/2021 RPM Base Residual Auction model for multiple study years
  - Determined RPM and Energy estimated benefits for proposed projects
- **Market Efficiency Status**
  - Project 201617\_1A-2A proposed by AEP to be recommended for board approval:
    - Upgrade terminal equipment at Tanners Creek 345kV station. Upgrade 345kV Bus and Risers at Tanners Creek for the Dearborn circuit.
    - Cost \$0.6 million
- **Additional Projects provide no incremental benefit**

- Base Case was updated with the portion of the reliability project 2017\_1-6A to be recommended in the Reliability Window 1 (see Appendix A)

CETL Analysis	Proposer	Project In-Service Year	Project Cost (\$M)	DEOK Price Separation?
Base				Yes
201617_1-1A	NTD	2021	\$12.70	No
201617_1-2A	AEP	2021	\$0.60	No
201617_1-2B	AEP	2021	\$4.90	No

**Project ID: 201617\_1A-1A**

Proposed by: Northeast Transmission Development (NTD)

Proposed Solution: Greenfield.

New 345 kV switching station ("Twelvemile"). Build a 345 kV switching station ("Twelvemile") interconnecting the existing Silver Grove - Zimmer 345 kV transmission line and the Pierce - Buffington 345 kV transmission line.

kV Level: 345 kV

In-Service Cost (\$M): \$12.7, B/C Ratio = 8.88

In-Service Date: 6/1/2021


Target Zone: DEOK LDA

ME Constraints:

TANNERS CREEK - MIAMI FORT 345 kV

Notes:

- Same project was submitted as 2017\_1-2E to the reliability window, PJM 2017 Proposal Window 1, to address reliability violations.
- This RPM project is not currently recommended.



Project ID: 201617\_1A-2A

Proposed by: American Electric Power (AEP)

Proposed Solution: Upgrade  
 Upgrade terminal equipment at Tanners Creek 345kV station  
 Upgrade 345kV Bus and Risers at Tanners Creek for the Dearborn circuit.

kV Level: 345 kV

In-Service Cost (\$M): \$0.6, B/C Ratio = 151.61

In-Service Date: 6/1/2021


Target Zone: DEOK LDA

ME Constraints:

TANNERS CREEK - MIAMI FORT 345 kV

Notes:

- **Very low cost**
- **Anticipate recommendation for Board approval in December 2017**
- **Designated Entity: AEP (the local TO)**



Project ID: 201617\_1A-2B

Proposed by: American Electric Power (AEP)

Proposed Solution: Upgrade  
 Establish Tanners Creek - Dearborn 345kV Circuit #2  
 Install two 345kV CB at Dearborn station for Tanners Creek Circuits #1 and #2 and one 345kV CB at Tanners Creek for Dearborn Circuit #2.

kV Level: 345 kV

In-Service Cost (\$M): \$4.9, B/C Ratio = 18.6

In-Service Date: 6/1/2021


Target Zone: DEOK LDA

ME Constraints:

TANNERS CREEK - MIAMI FORT 345 kV

Notes:

- Cost higher and B/C ratio lower than 201617\_1A-2A proposal
- This RPM project is not currently recommended.





- PJM anticipates that the Market Efficiency baseline solution 201617\_1A-2A proposed by AEP will be presented to the PJM Board in December and recommended for inclusion in the RTEP.

# Appendix A

## Portion of 2017\_1-6A

(Preliminary Reliability Recommendation  
DEOK Transmission Zone)



# Reliability Recommendation DEOK Transmission Zone

## Preliminary Recommendation: (Portion of 2017\_1-6A)

Install a new 345kV breaker "1422" so Pierce 345/138kV transformer #18 is now fed in a double breaker, double bus configuration.

Remove X-533 No. 2 to the first tower outside the station. Install a new first tower for X-533 No.2.

Install new 345KV breaker B and move the Buffington-Pierce 345kV feeder to the B-C junction. Install a new tower at the first tower outside the station for Buffington-Pierce 345kV line.


Remove breaker A and move the Pierce 345/138kV transformer #17 feed to the C-D junction.

Replace breaker 822 at Beckjord 138kV substation to increase the rating from Pierce to Beckjord 138kV to 603MVA.

**Estimated Project Cost: \$ 9.17 M**

**Required IS date: 6/1/2021**

**Project Status: Conceptual**



- V1 – 10/30/2017 – Original Slides Posted