

## Market Efficiency Update

Transmission Expansion Advisory Committee August 8, 2019 Nick Dumitriu, Market Simulation

PJM TEAC – 08/08/2019 PJM©2019



# 2018/19 Market Efficiency Window

PJM TEAC – 08/08/2019 2 PJM©2019



### 2018/19 Window Mid-Cycle Base Update

- Rating correction for LNG-Maple 138kV (NIPS) line
  - » MISO Project ID 15384 (BaseRel)
  - » Already included in MTEP18
- Small bus mapping/weights corrections for the PROMOD definition of several ARR hubs
- Updated posting on the Market Efficiency secure page as zip file
  - 201819ME PJM Base Case Update v2019-07-26.zip
  - https://www.pjm.com/planning/rtep-development/market-efficiency/economic-planningprocess.aspx
- Zip file includes one .xml and two .eve files:
  - PROMOD XML file (to be added to the current base case scenario)
  - Updated event files (Base Case and FSA Sensitivity)



#### 2018/19 Market Efficiency Window Analysis Status

- Data validation for all projects
- N-1 contingency analysis for all proposals ✓
- PROMOD modeling of all proposals ✓
- Base Case and FSA Sensitivity simulations ✓
  - Base Case updated with the Maple-LNG rating increase ✓
- Updated Interregional PJM B/C ratios ✓
  - Bosserman -Trail Creek and Marblehead proposals
  - B/C ratios computed using the submitted in-service cost of components (full cost)
  - MISO benefits not included in B/C ratios
- Completed Reliability Analysis for Interregional proposals ✓
  - No reliability issues found

PJM TEAC – 08/08/2019 PJM©2019



Updated Preliminary Results for Interregional Proposals

PJM TEAC – 08/08/2019 5 PJM©2019



### Bosserman-Trail Creek Proposals Preliminary Results

Proposal ID	BT_436	BT_481*	BT_129	BT_249	BT_398
Proposal Description	New Toto 345kV station	Rebuild Michigan City-Trail Creek-Bosserman 138 kV (10.7mi)	New Kuchar station and new Kutchar-Luchtman 138kV line (10.5mi)	50 MW 4-hour battery at Trail Creek 138 kV station	New Meadow Lake-Pike Creek 345kV line (63.4mi)
Project Type	Greenfield	Upgrade	Greenfield	Greenfield	Greenfield
B/C Ratio Metric	Lower Voltage	Lower Voltage	Lower Voltage	Lower Voltage	Lower Voltage
In-Service Cost (\$MM)**	\$19.31	\$20.99	\$27.62	\$45.40	\$266.44
Cost Containment	Yes	No	Yes	Yes	No
In-Service Year	2023	2023	2023	2023	2023
% Cong Driver Mitigated	38%	100%	95%	93%	52%
2023 Shifted Cong (\$MM)	-	\$0.04	-	\$2.89	-
Base Case B/C Ratio*	2.34	3.10	2.04	0.66	0.36
FSA Sens. B/C Ratio*	4.67	6.04	4.70	1.14	0.53
Мар	Monkey City Council Ent Ex Council Cou	Belly Control of the	City  Michigan City  Luchtman  Luchan  Luchan  Luchan	City  Trail Creek  Marnke  Marnke	Addition of the Control of the Contr

<sup>\*</sup>Base Case updated with the Maple-LNG rating increase. This update eliminated the need for upgrading Maple-LNG 138 kV as part of proposal. \*\*Costs under review by PJM



#### Marblehead Transformer Proposals Preliminary Results\*

Proposal ID	MH_322	MH_506	
Proposal Description	Rebuild Palmyra-Marblehead 161 kV and Marblehead-Herleman 138 kV lines (12mi). New 345 kV ring bus at the Palmyra substation.	Rebuild Palmyra-Marblehead 161 kV and Marblehead- Herleman 138 kV lines. New Maywood-Palmyra 345 kV line (15mi).	
Project Type	Upgrade	Greenfield	
B/C Ratio Metric	Lower Voltage	Lower Voltage	
In-Service Cost (\$M)**	\$35.95	\$36.02	
Cost Containment	No	No	
In-Service Year	2023	2023	
% Cong Driver Mitigated	100%	100%	
2023 Shifted Cong (\$MM)	\$0.11	\$0.13	
Base Case B/C Ratio*	0.36	0.68	
FSA Sens. B/C Ratio*	0.18	0.16	
Мар	Colimyton  Construction of Colomyton  Colomyton  Construction of Colomyton  Construction of Colomyton  Colomyton	Concy  Characteristics  Characteristics	

<sup>\*</sup>Base Case updated with the Maple-LNG rating increase

PJM TEAC – 08/08/2019 7 PJM©2019

<sup>\*\*</sup>Costs under review by PJM



#### Interregional Proposals Summary

#### Bosserman – Trail Creek 138 kV

- Rating correction for LNG-Maple 138kV (NIPSCO) line removed the congestion shifted to this line and eliminated the need for upgrading Maple-LNG 138 kV as part of proposal BT\_481.
- Two lower cost proposals, BT\_481 and BT\_129, substantially relieves congestion on the driver without shifting congestion.

#### Marblehead Transformer

None of the proposals pass the B/C Ratio threshold of 1.25 in the latest base case.

#### Monroe – Wayne 345 kV

- None of the proposals significantly decrease the total congestion around the Monroe bus.
   All three proposals shift congestion to parallel Monroe Brownstone 345 kV line.
- Analysis presented at June 2019 TEAC (slide 11)

https://www.pjm.com/-/media/committees-groups/committees/teac/20190613/20190613-market-efficiency-update.ashx



- Interregional Proposals
  - Coordination with MISO on interregional proposal B/C ratios
- Continue Market Efficiency Analysis Hunterstown Lincoln Proposals
  - Focus on candidates that fully address congestion
  - Analysis of shifted congestion
- Complete Reliability Analysis for Hunterstown Lincoln proposals
- Complete RPM benefit analysis
- Complete Cost/Constructability Analysis for all proposals



## **Revision History**

08/05/2019 – V1 – Original version posted to pjm.com