



Initial Review and Screening 2020 RTEP Proposal Window 3

December 1, 2020

For Public Use



This page is intentionally left blank.

2020 RTEP Proposal Window No. 3

As part of its 2020 RTEP process cycle of studies, PJM identified clustered groups of flowgates that were put forward for proposals as part of 2020 RTEP Window No. 3. Specifically discussed in this Initial Review and Screening report - includes those flowgates listed in **Table 1**.

Table 1. 2020 RTEP Window No. 3 List of Flowgates

Flowgates	Voltage Level	Driver
AEP-T431, AEP-T464, AEP-T475, AEP-T430, AEP-T474, AEP-T485, AEP-T473, AEP-T484, AEP-T472, AEP-T483, AEP-T471, AEP-T482, AEP-T470, AEP-T481, AEP-T480, AEP-T429, AEP-T469, AEP-T424, AEP-T479, AEP-T467, AEP-T478, AEP-T466, AEP-T477, AEP-T476	69 kV, 138 kV	Thermal

Proposals Submitted to PJM

PJM conducted 2020 RTEP Proposal Window No. 3 for 30 days beginning September 18, 2020 and closing October 19, 2020. During the window, several entities submitted three proposals through PJM’s Competitive Planner Tool. The proposals are summarized in **Table 2**. Publicly available redacted versions of the proposals can be found on PJM’s web site: <https://www.pjm.com/planning/competitive-planning-process/redacted-proposals.aspx>.

Table 2. 2020 RTEP Proposal Window No. 3 List of Proposals

Proposal ID#	Project Type	Project Description	Estimated Total Construction Cost (\$, millions)	Cost Capping Provisions (Y/N)
860	Upgrade	North Woodcock-East Leipsic 69 kV Line	12.93	N
533	Greenfield	East Leipsic-New Liberty 138 kV Line Conversion	21.13	Y
697	Upgrade	Richlands-East Leipsic 138 kV Line	1.29	N

Initial Review and Screening

PJM has completed an initial review and screening of the proposals listed in **Table 2** above based on data and information provided by the project sponsors as part of their submitted proposals. This review and screening included the following preliminary analytical quality assessment:

- *Initial Performance Review* – PJM evaluated whether or not the project proposal solved the required reliability criteria violation drivers posted as part of the open solicitation process.
- *Initial Planning Level Cost Review* – PJM reviewed the estimated project cost submitted by the project sponsor and any relevant cost containment mechanisms submitted as well.

- *Initial Feasibility Review* – PJM reviewed the overall proposed implementation plan to determine if the project, as proposed, can feasibly be constructed.
- *Additional Benefits Review* – PJM reviewed information provided by the proposing entity to determine if the project, as proposed, provides additional benefits such as the elimination of other needs on the system

Initial performance reviews yielded the following results:

1. No significant difference among the three proposals as to their respective ability to solve the identified reliability criteria violations.
2. No creation of additional reliability criteria violations.

Initial cost reviews showed cost commitment provisions from Proposal No. 533 that, in summary, would cap total rate base recovery; Proposal Nos. 860 and 697 did not contain cost commitment provisions.

PJM also notes that Proposal No. 533 incorporates greenfield construction that will require new or additional easements, and siting of a new 345kV substation. The proposing entity believes that the existing Gambier 69V substation can be expanded inside the existing substation fence line to accommodate a new 69kV line from the new 345kV substation. This siting of a new 345kV substation offers some significant risk to the proposal.

A high level review of the plans identified in each of the proposals did not reveal any other concerns at this stage of review.

Additional Benefits

To facilitate PJM's identification of more efficient or cost effective transmission solutions to identified regional needs, PJM may consider the secondary benefits a proposal window-submitted project may provide beyond those required to solve identified reliability criteria violations. As discussed in Section 1.1 and Section 1.4.2 of PJM Manual 14B, Transmission Owner Attachment M-3 needs and projects are to be reviewed to determine any overlap with solutions proposed to solve the violations identified as part of opening an RTEP proposal window.

A review of these overlaps as part of PJM's 2020 Window No. 3 screening has identified secondary benefits beyond solving identified reliability criteria violations. Based on the information provided by the sponsor, Proposal No. 860 will address needs associated with aging infrastructure as outlined below:

- Project will replace a 1950's wood pole line that utilizes copper conductor. Proposal will also replace a 1952 vintage 138/69 kV transformer along with a 1951 oil breaker at West Mount Vernon station.

Mount Vernon-West Mount Vernon 69 kV Circuit (4.68 miles)

- From 2015 – 2020 this circuit has experienced 2 momentary and 5 permanent outages resulting in approximately 21k CMI.
- The circuit currently has 45 open conditions on 38 structures (49% of the total structures), including pole damage, rot top, rot heart, and missing ground lead wires.

- Structures are made up of wood poles from the 1950s (50 structures). Some structures have been replaced since the 1980s (28 structures).
- The circuit conductor was installed in 1952 consisting of 3/0 Copper.

Initial Review Conclusions and Next Steps

Proposal No. 860 solves the identified reliability criteria violations and offers additional benefits in the form of eliminating an Attachment M-3 need (not observed in the other proposals in this cluster). Proposal No. 697, while indicating less costs for the individual proposal, will not address the existing aging infrastructure issues identified above. Proposal No. 533 offers to solve the violations through addition of a source to the Gambier 69kV substation, which currently does not have facilities with which it might serve the load in the area but would be required should the Attachment M-3 need (indicated as additional benefits for Proposal No. 860) be left unresolved in the future. This would lead to a need for further expansion at the Gambier substation to provide transformation capabilities, as well as additional circuits from Gambier, to serve load addressed in the facilities identified in the additional benefits for Proposal No. 860.

In addition to being more costly, Proposal No. 533 incorporates greenfield construction which may impact the ability to timely complete the project, while Proposal No. 860, in contrast, is an upgrade to existing facilities. Finally, while cost capping provisions are provided in Proposal No. 533, the costs for Proposal No. 533 are significantly higher than the costs estimated for Proposal No. 860.

Based on this information, Proposal No. 860 appears to be the more efficient or cost effective solution in Window No. 3. PJM's initial planning level cost review and initial feasibility review suggests that further constructability review and financial analysis would not materially contribute to the analysis of the other proposals submitted for this cluster.

PJM anticipates conducting a final review that PJM intends to share with stakeholders at the January TEAC after which a final recommendation will be made to the PJM Board for review and approval.