

Market Efficiency Update

Nick Dumitriu
Sr. Lead Engineer, Market Simulation
Transmission Expansion Advisory Committee
December 1, 2020



20/21 Long Term Window



- 20/21 Market Efficiency Analysis Assumptions whitepaper
- Market Efficiency Training, available <u>here</u> completed October 20th
- Materials posted on the <u>Market Efficiency page</u>
 - PROMOD 11.3 Test Case Results and B/C Ratio Example Workbook
 - ARR spreadsheet
- Retooled Market Efficiency Base Case and Sensitivities XML (PROMOD 11.3)
 - To be posted in the following days
- 20/21 Market Efficiency Long-Term Window to open January 11, 2020 (120 days)
 - Final ME Window Congestion Drivers, ME Window Base Case, and Sensitivity scenarios to be posted before start of 20/21 Long-Term Window



- Retooled model includes MISO data update
 - Updated PJM Generation Expansion (ISA/FSA status, retirements)
 - Updated topology using the retooled 2025 powerflow from Transmission Planning
 - Also updated PJM line ratings and contingency definitions
 - ABB-Hitachi PROMOD data updates (heat rates, generator outages, some solar profiles)
 - Input data corrections based on the feedback received from the stakeholders
 - Updated PROMOD setup and reporting switches

Updated Demand Forecast and Gas Price Forecast to account for COVID-19 impact



PJM Peak Demand and Energy Forecast


| Load Forecast | 2021 | 2025 | 2028 | 2031 | 2035 |
|---------------|---------|---------|---------|---------|---------|
| Peak (MW) | 149,616 | 153,315 | 156,014 | 157,637 | 159,868 |
| Energy (GWh) | 789,236 | 817,966 | 834,225 | 843,471 | 857,016 |

Notes:

- 1. Peak and energy values for 2025 onward are from the PJM Load Forecast Report Table B-1 and Table E-1, respectively.
- 2. Peak and energy values for 2021 are from the July 2020 Load Forecast Update.
- Model inputs are at the zonal level. To the extent zonal load shapes create different diversity, modeled PJM peak load may vary.



Gas Price Forecast Update



Note: Gas – Annual average Henry Hub price



Base Case Updated Preliminary Results - PROMOD Simulated Congestion 1

| Group** | Correlated Historical Constraints ² | Congested Area Type Day Ahea | | Historical 2019 Day Ahead Congestion | ŀ | Historical 2020 Day Ahead Congestion | S | Simulated 2025 Congestion | | Simulated 2028 Congestion | |
|---------|--|-----------------------------------|------|--------------------------------------|-----------|--------------------------------------|------------|------------------------------|------------|------------------------------|------------|
| 1 | Harwood to Susquehanna 230 kV | PPL ³ (Susq. Group) | Line | \$ | 6,054,821 | \$ | 19,448,223 | \$ | 20,388,443 | \$ | 16,470,054 |
| 2 | Cumberland to Juniata 230 kV | PPL ³ | Line | \$ | 3,516,896 | \$ | 6,368,984 | \$ | 6,368,984 | \$ | 6,368,984 |
| 2 | Dauphin to Juniata 230 kV | | Line | \$ | - | \$ | 472,479 | \$ | - | \$ | - |
| 2 | Juniata 500/230 kV | (Juniata group) | XFRM | \$ | | \$ | 2,883,545 | \$ | | \$ | |
| 3 | Plymouth Meeting to Whitpain 230 kV | PECO | Line | \$ | 2,511,244 | \$ | 3,759,112 | \$ | 5,767,262 | \$ | 6,394,857 |
| 4 | Cherry Run to Morgan 138 kV | | Line | \$ | 883,588 | \$ | - | \$ | 3,463,430 | \$ | 4,115,481 |
| 4 | Jct. to French's Mill 138 kV | | Line | \$ | 116,952 | \$ | 345,506 | \$ | 4,966,217 | \$ | 5,891,888 |
| 4 | Gore to Stonewall 138 kV | APS | Line | \$ | 818,902 | \$ | 177,599 | \$ | 25,066,669 | \$ | 35,000,841 |
| 4 | Messick Road to Morgan 138 kV | | Line | \$ | 263,290 | \$ | - | \$ | - | \$ | - |
| 4 | Messick Road to Ridgeley 138 kV | | Line | \$ | 1,704,272 | \$ | 462,027 | \$ | | \$ | |
| 5 | Kammer North to Natrium 138 kV | AEP | Line | \$ | 178,984 | \$ | 36,523 | \$ | 2,540,399 | \$ | 12,215,076 |
| 6 | Quad Cities to Rock Creek 345 kV | CE-ALTW | M2M | \$ | 896,048 | \$ | 427,688 | \$ | 6,347,712 | \$ | 9,005,279 |
| 7 | Muskingum River to Beverly 345 kV | AEP | Line | \$ | - | \$ | - | \$ | 1,086,660 | \$ | 2,185,014 |
| 8 | Muskingum River to Waterford 345 kV | AEP | Line | \$ | - | \$ | | \$ | 1,131,018 | \$ | 1,182,204 |

Notes:

- 1) Preliminary results, not final congestion drivers. List of constraints and congested areas may change in the final base case.
- 2) Table identifies correlated historical constraints with 2025 PROMOD simulated congestion in the same area/group.
- 3) Cumberland Juniata and Harwood Susquehanna Congestion drivers may be impacted by DLR (Dynamic Link Rating) projects (expected in-service date 06/01/2021)

Base Case Updated Preliminary Results - PROMOD Simulated Congestion 1

| Group** | Correlated Historical Constraints ² | Congested Area | Туре | Historical 2019 Day Ahead Congestion | | Н | Historical 2020 Day Ahead Congestion | | Simulated 2025 Congestion | Simulated 2028 Congestion |
|---------|--|-------------------|------|--------------------------------------|---------|----|--|----|------------------------------|------------------------------|
| 9 | Maliszewski Transformer 765/138 kV | AEP | Line | \$ | - | \$ | - | \$ | 4,024,754 \$ | 5,639,132 |
| 10 | Charlottesville to Proffit Rd Del Pt 230 kV | DOM | Line | \$ | - | \$ | 441,875 | \$ | 2,795,987 \$ | 2,920,445 |
| 11 | Brambleton to Evergreen Mills 230 kV | DOM | Line | \$ | 390,310 | \$ | - | \$ | 1,403,659 \$ | 7,736,793 |

Notes:

- 1) Preliminary results, not final congestion drivers. List of constraints and congested areas may change in the final base case.
- 2) Table identifies correlated historical constraints with 2025 PROMOD simulated congestion in the same area/group.



2020 Annual Reevaluation of Market Efficiency Projects



- PJM is required by Schedule 6 of the Operating Agreement (OA) to "annually review the cost and benefits" of Board-approved market efficiency projects that meet certain criteria to assure that a project continues to be cost beneficial.
- The annual reevaluation is not required for projects that have commenced construction or have received state siting approval.
 - See Appendix A for list of projects with status of In-Service, Under Construction or Cancelled.
- Analysis will utilize the most recent Market Efficiency case available



- The PJM Board approved project b3142 (BT-481), the rebuild of Michigan City to Trail Creek to Bosserman138kV lines, December 3, 2019
 - The approval was conditional on MISO approval of same project
- MISO Project (P18585) approved by MISO Board of Directors on September 17, 2020
 - Project approval was pending the approval of MISO regional cost allocation by FERC, which occurred on July 28, 2020
 - Project Status: Under Construction
 - NIPSCO to provide quarterly status reports consistent with MISO Tariff requirements, which will be posted <u>here</u>



- Reevaluation of projects b2697, b2976, b3145 has been completed
 - All projects pass the 1.25 threshold
 - Results included in Appendix B

 Reevaluation process for 201415_1-9A (b2743.2-8, b2752.1-9) to be completed and results posted by end of the year.



2020 Acceleration Analysis



Scope

 Determine which previously approved <u>Reliability</u> upgrades, if any, have an economic benefit if accelerated or modified

Study Years

 2021 and 2025 set of economic input assumptions used to study impacts of approved RTEP projects

Process

- Compare market congestion for near term vs. future topology
- Estimate economic impact of accelerating planned reliability upgrades

Acceleration Analysis Status

- Work completed
 - Finalized PROMOD modeling for AS-IS and RTEP topology cases
 - Compiled the list of potential candidates from previously approved reliability upgrades
- Complete PROMOD simulations
 - 2021 and 2025 study years with 2021 Topology (AS-IS Topology)
 - 2021 and 2025 study years with 2025 Topology (RTEP Topology)
- Acceleration analysis to be completed by December 2020 and results posted by the end of the year.





| Step | Timeline |
|--|-------------------------|
| Post Preliminary Congestion Drivers | November 2020 |
| Finalize 2020 Reevaluation Analysis | December 2020 |
| Finalize 2020 Acceleration Analysis | December 2020 |
| Post Final Base Case and Target Congestion Drivers | December 2020 |
| Long Term Proposal Window (120 Days) | Opens January 11th 2021 |
| Mid-Cycle Update | February – April 2021 |
| Analysis of Proposed Solutions | May – September 2021 |
| TEAC Reviews and Board Approval | October – December 2021 |



Dynamic Line Ratings Market Efficiency Modeling



DLR technology does not modify the physical characteristics of a line, but rather provides a means for determining instant line ratings more precisely by using specialized sensors that provide a more precise indication of the current ratings.



- Market efficiency base case uses planning seasonal ratings
 - Summer Normal & Emergency, Winter Normal & Emergency
- Accounting for DLR in market efficiency base case:
 - Ratings for lines equipped with DLR devices will be modeled using a DLR Hourly Rating Modifier on top of the Planning seasonal ratings
 - The DLR Hourly Rating Modifier will be calculated as the forecasted hourly difference between forecasted DLR ratings and ambient-ratings for the DLR line



- Further information to be shared at future TEAC (Transmission Expansion Advisory Committee) meetings.
- PJM to update congestion drivers as applicable.
- Modeling document to-be posted.



Appendix A Market Efficiency Projects In-Service, Under Construction or Cancelled



In-Service, Under Construction or Cancelled Projects

| | | | | | | 1000 | |
|--------------------------|-----------|---------|---------|--|--------|--|---|
| PJM Window Project ID | Baseline# | Туре | Area | Constraint | Status | ISD | Description |
| 201415_1-2B | b2691 | Upgrade | ME/PPL | Brunner Island to Yorkana 230 kV | IS | 6/12/2017 | Reconductor three spans limiting Brunner Island - Yorkana 230 kV line, add 1 breaker to Brunner Island switchyard, upgrade associated terminal equipment |
| 201415_1-4J | b2698 | Upgrade | AEP | Jacksons Ferry to Cloverdale 765 KV | IS | 12/8/2017 | Replace relays at Cloverdale and Jackson's Ferry substations |
| 201415_1-10B | b2693 | Upgrade | COMED | Wayne to South Elgin 138 kV | IS | 11/1/2018 | Replace L7915 B phase line trap at Wayne substation |
| 201415_1-10D | b2728 | Upgrade | COMED | Loretto to Wilton 345 kV (RPM) | IS | 12/22/2017 | Mitigate sag limitations on Loretto - Wilton Center 345 kV Line and replace station conductor at Wilton Center |
| 201415_1-12A | b2689.1-3 | Upgrade | DUQ | Dravosburg to West Mifflin 138 kV | IS | 1: 3/2/2018 2: 6/8/2018 3: 12/6/2017 | Reconductor ~7 miles of the Woodville - Peters 138 kV circuit. Reconfigure West Mifflin-USS Clairton 138 kV circuit. Upgrade terminal equipment |
| 201415_1-13E | b2695 | Upgrade | DPL | Worcester to Ocean Pines (I) 69 kV | IS | 12/31/2017 | Rebuild Worcester - Ocean Pine 69 kV ckt. 1 |
| 201415_1-18G | b2688.1-3 | Upgrade | APS | Taneytown to Carroll 138 kV | IS | 1: 10/5/2018 2: 4/18/2018 3: 5/25/2018 | Upgrade terminal equipment on the Lincoln - Carroll 115/138kV path. |
| 201415_1-2A | b2690 | | PPL/BGE | | IS | 10/18/2017 | Reconductor two spans of the Graceton - Safe Harbor 230 kV transmission line |
| 201415_1-18I | b2696 | Upgrade | APS/ATS | Krendale to Shanor Manor 138 kV | IS | 12/10/2018 | Upgrade 138 kV substation equipment at Butler, Shanor Manor and Krendale substations |
| 201415_1-10J | b2692.1-2 | Upgrade | COMED | Cordova to Nelson 345 kV | IS | 5/8/2019 | Replace station equipment at Nelson, ESS H-471 and Quad Cities. Upgrade conductor ratings of Cordova - Nelson, Quad Cities - ESS H-471 and ESS H-471 - Nelson 345 kV lines and mitigating sag limitations |



In-Service, Under Construction or Cancelled Projects, cont.

| PJM Window Project ID | Baseline# | Туре | Area | Constraint | Status | ISD | Description |
|--------------------------|------------------|---------|--------|---|--------|------------|--|
| 201415_1-11H | b2694 | Upgrade | PECO | Peach Bottom 500 kV | IS | 4/1/2019 | Increase ratings of Peach Bottom 500/230 kV transformer |
| Optimal Caps | b2729 | Upgrade | DOM | AP-South | IS | 1/30/2020 | New capacitor banks at Brambleton, Ashburn, Shelhorn and Liberty substations |
| 201617_1-3A | b2930 AC1-223 | Upgrade | COMED | E. Frankfort to University Park 345 kV | CANC | Cancelled | Upgrade capacity on E. Frankford-University Park 345kV |
| 201617_1-3B | b2931 (RPM) | Upgrade | COMED | Pontiac to Brokaw 345 kV | UC | 6/1/2021 | Upgrade substation equipment at Pontiac Midpoint station |
| 201617_1-5E | b2992.1-4 | Upgrade | BGE | Conastone - Graceton - Bagley 230 kV | UC | 6/1/2021 | Reconductor the Conastone to Graceton 230 kV 2323 & 2324 circuits. Add Bundle conductor on the Graceton-Bagley-Raphael Road 2305 & 2313 230kV circuits. Reconductor Raphael Road - Northeast 2315 & 2337 circuits. |
| 201819_BT_481 | b3142 | Upgrade | NIPSCO | Michigan City – Trail Creek - Bosserman 138 kV | UC | 01/01/2023 | Rebuild Michigan City-Trail Creek - Bosserman 138 kV (10.7 mi) |

IS – In-service UC – Under Construction CANC - Canceled



Appendix B 2020 Reevaluation Results Proposals b2697, b2976, b3145



Overview

- Projects with capital cost under \$20 million are reevaluated using the original benefits* and updated capital costs.
- 2020 Reevaluation B/C ratios for b2697, b2976, b3145

| PJM Window Project ID | Baseline# | Туре | Area | Constraint | Initial Capital Cost (\$ million) | | Current Status | Projected ISD | Updated Capital Cost** | 2020 Reevaluation B/C Ratio |
|--------------------------|-----------|---------|-------|--|-----------------------------------|--------|-------------------|--------------------------------|------------------------------|-----------------------------------|
| 201415_1-41 | b2697.1-2 | Upgrade | AEP | Fieldale to Thornton 138 kV | \$0.75 | 101.19 | EP | 1: 10/01/2020 2: 06/03/2021 | \$2.70 | 28.11 |
| 201617_1A_RP M_DEOK | b2976 | Upgrade | DEOK | Tanners Creek to Dearborn 345 kV | \$0.60 | 151.61 | EP | 3/4/2021 | \$0.60 | 151.61 |
| 201819_HL_622 | b3145 | Upgrade | METED | Hunterstown to Lincoln 115 kV | \$7.21 | 59.45 | EP | 6/1/2023 | \$7.21 | 59.45 |

^{*}Original benefits are the benefits that were determined when the projects were initially approved

^{**}Capital costs updated as of 11/23/2020



Facilitator:

Sue Glatz,

Suzanne.Glatz@pjm.com

Secretary:

Ilyana Dropkin,
Ilyana.Dropkin@pjm.com

SME/Presenter:

Nick Dumitriu,

Nicolae.Dumitriu@pjm.com

Market Efficiency Update



Member Hotline

(610) 666 - 8980

(866) 400 - 8980

custsvc@pjm.com



V1 – 11/25/2020 – Original slides posted