



# 2020 Summer Emergency Procedures Drill

June 2, 2020

- Review of emergency procedures
- Find deficiencies
- Prepare operators for real time emergency procedures
- Many companies were working from multiple control rooms

- Deviations in all calls vs. script
- Some distribution companies were unaware of the drill in advance
- An incorrect EDART number was given in the ALL Call for the Reactive Reserve Check
- Suggest it would be good for the TO Control Room Engineers to participate and interact with the PJM Reliability Engineer

- Load dump script needs to be updated
- Implementing a drill version of emergency procedures
- Any feedback or suggestions for future drills?

- CEH

- [Trainingsupport@pjm.com](mailto:Trainingsupport@pjm.com)

Drill Participation Form: <https://pjm.com/training/member-training-liaison.aspx>