



Manual 13 Revision 70: Cover to Cover Review

Augustine Caven
Sr. Lead Engineer, Generation
SOS
May 2, 2019

Action Required	Deadline	Who May Be Affected
Resource Limitation Reporting via new Markets Gateway Page in place of Supplemental Status Report (SSR)	6/1/2019	Generation Owners



Substantive Changes: Resource Limitation Reporting via Markets Gateway

- Terminology related to “Fuel Limited” units changed to “**Resource Limited**” to clarify applicability of reporting requirements.
 - Units considered Resource Limited if less than 72 hours of runtime at maximum capacity remaining limited by primary/alternate fuel, emissions, demineralized or cooling water, other consumables
- References to Supplementary Status Report (SSR) for reporting resource limitations removed and replaced with instructions to use **new Markets Gateway** page
 - Generator > Unit > Resource Limitations. Targeted for implementation 6/1/2019.
- New Exhibit added to Section 6.4 clarifying Resource Limitation Reporting and Notification requirements by Unit/Fuel type and Restriction type
- Impacted Sections:
 - Updates to Sections 1.1, 2.3, 2.5, **3.1**, 3.2, 3.3, 3.4, 3.5, 5.1, 5.2, **6.4**, Attachment B
 - **Attachment C**: Supplementary Status Report removed

Resource Limitation Reporting: Daily Fuel Limited Gas-Fired Units

- Gas-fired CT/Steam units with daily fuel limitations are considered Resource Limited if they have **less than 24 hours** runtime at maximum capacity, and should be reported via new Markets Gateway page.
- Gas-fired CT/Steam units with minimum level daily fuel limitations (**less than 8 hours** runtime at maximum capacity) should make a verbal notification to PJM dispatch.
- When PJM has declared Conservative Operations/Hot or Cold Weather Alert, Gas-fired CT/Steam units that are daily fuel limited < 8 hours should remain available for economics, to ensure that PJM tools economically schedule the units, unless PJM Dispatch directs that they are placed in Maximum Emergency.
 - This change was made to align with existing language in the PJM Operating Agreement for designating fuel limited resources as Maximum Emergency.

- Section 2.2 – Removed reference to SERC BAL-002 reserve policy (retired). Updated RF BAL-002 document link and naming from ‘Requirement’ to ‘Regional Criteria’.
- Section 2.4.7 – Updated M-3 section reference section 3.7
- Section 4.1, 4.3, 4.4, 4.5 – Removed of mention of Supplementary Status Report (SSR) where not needed
- Section 4.4.3 – updated link and version number to the new NERC Reliability Guideline: Generating Unit Operations During Complete Loss of Communications – Version 3
- Section 7.1 – Revised email address from dispsup@pjm.com to EOP011forms@pjm.com
- Attachments E and F – Tables updated with values for 2019

- First Reads
 - SOS: 4.4.2019
 - OC : 4.9.2019
 - MIC: 4.10.2019
 - MRC: 4.25.2019

- Second Reads / Endorsement
 - **SOS: 5.2.2019**
 - OC: 5.14.2019
 - MIC: 5.15.2019
 - MRC: 5.30.2019
 - Effective: 5.30.2019