

Attachment E: Automatic Sectionalizing Schemes

Atlantic City Electric Company (ACE)

1. **Churchtown - Beckett – Paulsboro 69 kV Sectionalized**– Restores Churchtown-Beckett or Beckett-Paulsboro following a fault on Beckett-Paulsboro or Churchtown-Beckett respectively.
 - Effective October 27, 2022
2. **Monroe - Glassboro – Rowan 69 kV Sectionalized**– Restores Monroe-Glassboro or Glassboro-Rowan following a fault on Glassboro-Rowan or Monroe-Glassboro respectively.
 - Effective October 27, 2022
3. **Monsanto - Nortonville – Oldman 69 kV Sectionalized**– Restores Monsanto-Nortonville or Nortonville-Oldman following a fault on Nortonville-Oldman or Monsanto-Nortonville respectively.
 - Effective October 27, 2022
4. **Pine Hill - Terrace – Pitman 69 kV Sectionalized**– Restores Pine Hill-Terrace or Terrace-Pitman following a fault on Terrace-Pitman or Pine Hill-Terrace respectively.
 - Effective October 27, 2022

Delmarva Power and Light (DPL)

1. **Basin Rd – Churchmans Tap – Keeney 138 kV Sectionalized**– Restores Basin Rd-Churchmans Tap or Churchmans Tap-Keeney following a fault on Churchmans Tap-Keeney or Basin Rd-Churchmans respectively.
 - Effective October 27, 2022