PJM Operations Summary

June 2024 Operations

June Events:

3 Shared Reserve Events

8 PCLLRW Events

7 Hot Weather Alert Events

1 Synchronized Reserve Event

CPS1: XXX.XX% CPS2: XX.XX% BAAL: XX.XX%

¹PJM directly measures the total number of BAAL excursions in minutes compared to the total number of minutes within a month with a target value for this performance goal at 99% on a daily and monthly basis. NERC rules limit the recovery period to no more than 30 minutes for a single event.

Shared Reserve (3 Events)

Effective	Effective		
Start Time	End Time	Message	Region
06.18.2024	06.18.2024	PJM provided 139 MW of NPCC Shared Reserves	NPCC
22:07	22:22		
06.18.2024	06.18.2024	PJM provided 77 MW of NPCC Shared Reserves	NPCC
17:25	17:40		
06.03.2024	06.03.2024	PJM received 65 MW of NPCC Shared Reserves	NPCC
18:56	19:35		

PCLLRW (8 Events)

Effective	Effective	Magaza	Danian
Start Time	End Time	Message	Region
06.24.2024	06.24.2024	A Post Contingency Local Load Relief Warning has been issued to	AEP
09:19	09:25	maintain MOTTVILL 138 KV BB_199 at 127.0 KV in the AEP for	
		Transmission Contingency Control.	
		Additional Comments: Post Contingency Switching available	
06.20.2024	06.20.2024	A Post Contingency Local Load Relief Warning has been issued to	FE-ATSI
15:04	17:02	maintain EAKRON-HAYELMRZ EAK-HAY at 229.0 MVA in the	
		FE(ATSI) for Transmission Contingency Control.	
		Additional Comments: Post Contingency Switching available	
06.19.2024	06.20.2024	A Post Contingency Local Load Relief Warning has been issued to	AEP
16:52	17:04	maintain SBUFFALO 138 KV *E01 at 127.0 KV in the AEP for	
		Transmission Contingency Control.	
		Additional Comments: Post Contingency Switching available	
06.19.2024	06.19.2024	A Post Contingency Local Load Relief Warning has been issued to	AEP
14:43	14:49	maintain REFORM -NNEWARK NNE-REF at 240.0 MVA in the	
		AEP for Transmission Contingency Control.	
		Additional Comments: Generation - slow response	
06.19.2024	06.19.2024	A Post Contingency Local Load Relief Warning has been issued to	FE-PN
13:57	15:28	maintain LENOX-NMESHOPP NML 1090 at 148.0 MVA in the	
		FE(PN) for Transmission Contingency Control.	
		Additional Comments: Load -No Generation or Switching	
		available	

PJM Operations Summary

June 2024 Operations

06.18.2024	06.18.2024	A Post Contingency Local Load Relief Warning has been issued to	AEP
14:19	14:31	maintain NDELPHOS-SDELPHOS NDE-SDE at 54.0 MVA in the AEP	
		for Transmission Contingency Control.	
		Additional Comments: Post Contingency Switching available	
06.17.2024		A Post Contingency Local Load Relief Warning has been issued to	FE-AP
15:13		maintain OPEQUON 138 KV 138-B at 127.0 KV in the FE(APS)	
		for Transmission Contingency Control.	
		Additional Comments: Load -No Generation or Switching	
		available	
06.17.2024	06.17.2024	A Post Contingency Local Load Relief Warning has been issued to	AEP
06:13	06:18	maintain MOTTVILL 138 KV BB_199 at 127.0 KV in the AEP for	
		Transmission Contingency Control.	
		Additional Comments: Post Contingency Switching available	

Hot Weather Alert (7 Events)

Effective	Effective		
Start Time	End Time	Message	Region
		A Hot Weather Alert has been issued from 07:00 on 06.26.2024	
		through 23:00 on 06.26.2024 Per M-13, members are expected	
		to perform:	
		TRANSMISSION/GEN DISPATCH review plans to determine if any	
		maintenance/testing, scheduled/being performed, on any	
06.26.2024	06.26.2024	monitoring, control, transmission/generating equipment can be	MIDATL,
07:00	23:00	deferred/canceled.	SOUTHERN
		A Hot Weather Alert has been issued from 07:00 on 06.25.2024	
		through 23:00 on 06.25.2024 Per M-13, members are expected	
		to perform:	
		TRANSMISSION/GEN DISPATCH review plans to determine if any	
		maintenance/testing, scheduled/being performed, on any	
06.25.2024	06.25.2024	monitoring, control, transmission/generating equipment can be	
07:00	23:00	deferred/canceled.	RTO
		A Hot Weather Alert has been issued from 07:00 on 06.24.2024	
		through 23:00 on 06.24.2024 Per M-13, members are expected	
		to perform:	
		TRANSMISSION/GEN DISPATCH review plans to determine if any	
		maintenance/testing, scheduled/being performed, on any	
06.24.2024	06.24.2024	monitoring, control, transmission/generating equipment can be	SOUTHERN,
07:00	23:00	deferred/canceled.	MIDATL
		A Hot Weather Alert has been issued from 07:00 on 06.17.2024	
		through 22:56 on 06.23.2024 Per M-13, members are expected	
06.17.2024	06.23.2024	to perform:	
07:00	22:56		RTO

PJM Operations Summary

June 2024 Operations

		TRANSMISSION/GEN DISPATCH review plans to determine if any maintenance/testing, scheduled/being performed, on any monitoring, control, transmission/generating equipment can be deferred/canceled.	
		A Hot Weather Alert has been issued from 07:00 on 06.16.2024 through 23:00 on 06.16.2024 Per M-13, members are expected to perform:	
06.16.2024 07:00	06.16.2024 23:00	TRANSMISSION/GEN DISPATCH review plans to determine if any maintenance/testing, scheduled/being performed, on any monitoring, control, transmission/generating equipment can be	MICTERN
07:00	23:00	deferred/canceled. A Hot Weather Alert has been issued from 07:00 on 06.14.2024	WESTERN
		through 23:03 on 06.14.2024 Per M-13, members are expected to perform:	
		TRANSMISSION/GEN DISPATCH review plans to determine if any maintenance/testing, scheduled/being performed, on any	
06.14.2024 07:00	06.14.2024 23:03	monitoring, control, transmission/generating equipment can be deferred/canceled.	MIDATL, SOUTHERN
		A Hot Weather Alert has been issued from 07:00 on 06.13.2024 through 23:00 on 06.13.2024 Per M-13, members are expected to perform:	
		TRANSMISSION/GEN DISPATCH review plans to determine if any maintenance/testing, scheduled/being performed, on any	
06.13.2024 07:00	06.13.2024 23:00	monitoring, control, transmission/generating equipment can be deferred/canceled.	RTO

Synchronized Reserve (1 Event)

Effective Start Time	Effective End Time	Message	Region
06.03.2024	06.03.2024	100% Synchronized Reserve Event has been initiated for the	RTO
18:53	19:02	PJM_RTO region.	

PJM Operations Summary

June 2024 Operations

Non-Market PCLLRW Events (0 Event(s))

High System Voltage (0 Event(s))

Geomagnetic Disturbance Action (0 Event(s))

Geomagnetic Disturbance Warning (0 Event(s))

Non-Market PCLLRW (0 Event(s))

Conservative Operations (0 Event(s))

Cold Weather Alert (0 Event(s))

Cold Weather Advisory (0 Event(s))

TLR (0 Event(s))

Maximum Generation Emergency/Load Management Alert (0 Event(s))

Maintenance Outage Recall (0 Events)

Unit Startup Notification Alert (0 Event(s))

Voltage Reduction Warning (0 Event(s))

Voltage Reduction (0 Event(s))

Manual Load Dump Event (0 Event(s))

Manual Load Dump Warning (0 Event(s))

Max Emergency Gen Alert (0 Event(s))

Max Emergency Generation (0 Event(s))

Min Gen Alert (0 Event(s))

Min Gen Declaration (0 Event(s))

Local Min Generation Event (0 Event(s))

HLV Schedule Warning (0 Event(s))

HLV Schedule Action (0 Event(s))

Primary Reserve Warning (0 Event(s))

Manual Load Dump Warning (0 Event(s))

Emergency Energy Request (0 Event(s))