West Cambridge Transformer Addition

General Information

Proposing entity name	AEPSCT
Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project?	Yes
Company proposal ID	AEP_E
PJM Proposal ID	920
Project title	West Cambridge Transformer Addition
Project description	AEP is proposing to install a second 138/69 kV transformer at West Cambridge station. The 69 kV bus will be reconfigured into a 3 breaker ring utilzing the existing 69 kV breaker 'F' along with two new 69 kV circuit breakers. The new transformer will be protected by a high side 138 kV circuit switcher. New transformer branch will be created between bus 243144 and 245483 with an initial SE/SN rating of 124/132 MVA. Existing branch ratings at West Cambridge station will not be changing as a part of this proposal.
Email	nckoehler@aep.com
Project in-service date	04/2025
Tie-line impact	No
Interregional project	No
Is the proposer offering a binding cap on capital costs?	No
Additional benefits	
Project Components	
1. West Cambridge Transformer Installation	

Substation Upgrade Component

Component title	West Cambridge Transformer Installation			
Project description	Install a second 138/69 kV transformer and associated sectionalizing at West Cambridge station. Reconfigure the 69 kV bus into a 3 breaker ring utilizing the existing 69 kV breaker 'F' along with two additional 3000A 40 kA 69 kV breakers			
Substation name	West Cambridge			
Substation zone	205 - AEP			
Substation upgrade scope	This scope will require the addition of a second box bay to the existing 138kV structures. This box bay will require the existing breaker and CCVTs for the Muskingum River line to be moved as well as switches for a new transformer. A second transformer with a circuit switcher will be added off of this box bay and connect to a new 69kV vertical ring bus. The existing 69kV structures for East Cambridge will be removed and replaced with a new 69kV ring bus utilizing existing 69 kv breaker 'F' along with two additional 69 kV circuit breakers.			
Transformer Information				
	Name	Capacity (MVA)		
Transformer	West Cambridge Transfomer #2 90			
	High Side	Low Side	Tertiary	
Voltage (kV)	138	69	12	
New equipment description	(Qty. 1) 3000A, 100kA, 3PH GC plus foundation (Qty. 1) 138/69/ Circuit Breakers plus foundation .6) Install strands of 138kV, 160 (Qty. 1) Install 3Ø, 69kV, 2000M (~450')	0AB Vee CB Switch (Qty. 1) 138k 12.47kV, 54/72/90MVA Transforr is (Qty. 4) 69kV, 3000A, 100kA, 3 0A strain bus (~ 40') with (3) 138 1CM strain bus between the 2 H-f	V, 3000A, 40kA Circuit Switcher ner (Qty. 2) 69kV, 3000A, 40kA BPH GOAB Vee CB switches (Qty kV, 1600A connection jumpers. Frame structures on the 69kV bus	
New equipment description Substation assumptions	(Qty. 1) 3000A, 100kA, 3PH GC plus foundation (Qty. 1) 138/69/ Circuit Breakers plus foundation .6) Install strands of 138kV, 160 (Qty. 1) Install 3Ø, 69kV, 2000M (~450') Station expansion and civil grad No major grounding upgrades/a	DAB Vee CB Switch (Qty. 1) 138k 12.47kV, 54/72/90MVA Transforr is (Qty. 4) 69kV, 3000A, 100kA, 3 0A strain bus (~ 40') with (3) 138 1CM strain bus between the 2 H-f ling work is minimal and can be d dditions will be required	V, 3000A, 40kA Circuit Switcher ner (Qty. 2) 69kV, 3000A, 40kA BPH GOAB Vee CB switches (Qty kV, 1600A connection jumpers. Frame structures on the 69kV bus one within the limits of the station.	
New equipment description Substation assumptions Real-estate description	 (Qty. 1) 3000A, 100kA, 3PH GC plus foundation (Qty. 1) 138/69/ Circuit Breakers plus foundation .6) Install strands of 138kV, 160 (Qty. 1) Install 3Ø, 69kV, 2000M (~450') Station expansion and civil grad No major grounding upgrades/a An expansion of the station in tw have drivability and maintainabil AEP property limits. 	DAB Vee CB Switch (Qty. 1) 138k 12.47kV, 54/72/90MVA Transforr is (Qty. 4) 69kV, 3000A, 100kA, 3 0A strain bus (~ 40') with (3) 138 1CM strain bus between the 2 H-F ling work is minimal and can be d dditions will be required vo separate areas will be required lity of the station. Both areas of p	V, 3000A, 40kA Circuit Switcher ner (Qty. 2) 69kV, 3000A, 40kA BPH GOAB Vee CB switches (Qty kV, 1600A connection jumpers. Frame structures on the 69kV bus one within the limits of the station. d in order to have the space to roposed expansion are within the	

Benefits/Comments

Component Cost Details - In Current Year \$	
Engineering & design	Detailed cost breakdown
Permitting / routing / siting	Detailed cost breakdown
ROW / land acquisition	Detailed cost breakdown
Materials & equipment	Detailed cost breakdown
Construction & commissioning	Detailed cost breakdown
Construction management	Detailed cost breakdown
Overheads & miscellaneous costs	Detailed cost breakdown
Contingency	Detailed cost breakdown
Total component cost	\$4,952,501.00
Component cost (in-service year)	\$.00
Congestion Drivers	

None

Existing Flowgates

FG #	From Bus No.	From Bus Name	To Bus No.	To Bus Name	СКТ	Voltage	TO Zone	Analysis type	Status
AEP -T39	245478	05LEATHERW	245489	05BROOMRD	1	69	205	FERC 715 Thermal	Included
AEP -T40	245478	05LEATHERW	245489	05BROOMRD	1	69	205	FERC 715 Thermal	Included
AEP -T41	245489	05BROOMRD	245493	05SALTFRKZ	1	69	205	FERC 715 Thermal	Included
AEP -T42	245489	05BROOMRD	245493	05SALTFRKZ	1	69	205	FERC 715 Thermal	Included

New Flowgates

None

Financial Information

Capital spend start date	01/2023
Construction start date	07/2024
Project Duration (In Months)	27

Additional Comments

None